



NOTES:

1) MiniCloset-5c handles up to four (4) PDM Modules with each PDM Module handling 12 discrete inputs (total of 48 discrete inputs). Ordering instruction:

PDM-A	Upto 12 pulse inputs
PDM-A,B	13 to 24 pulse inputs
PDM-A,B,C	25 to 36 pulse inputs
PDM-A,B,C,D	37 to 48 pulse inputs

2) Water, gas, BTU, et. al. meters must be dry contact output type. (Form A - See specifications for details. Contact Manufacturer for more information.)

3) All electric and pulse data can be collected via Power Line Carrier to the Scan Transponder.

REVISIONS			
REV.	DESCRIPTION	DATE	APPROVED

		Quadlogic Controls Corporation		TITLE MC-5c with PDM Installation Diagram	
SIGNATURES		DATE		SIZE DRAWING	
MODEL JREA		07/10/08		17-MC5c PDM MOD REV1	
DETAIL		APPROVED JKIM		REV 1.1.R	
APPROVED		07/10/08		SCALE:	
APPROVED				SHEET 1 of 1	